



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7300-1335:0105
<b>CATEGORY:</b>	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
<b>LISTEE:</b>	Altronix 140 58th Street, Bldg A, Ste 2N, Brooklyn, NY, 11220 Contact: Zatz, Gary (718) 567-8181 (718) 567-9056 Email: garyz@altronix.com
<b>DESIGN:</b>	Model MOM5 and MOM5C multi-output power module. Unit is designed for use with listee's Model AL400ULM power supply (CSFM Listing No. 7315-1335:100) or Model AL600ULM power supply (CSFM Listing No. 7315-1335:104) to provide five outputs for door holders, door strikes or similar devices. Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	12 or 24 VDC
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating and UL label.
<b>APPROVAL:</b>	Listed as an accessory for use with listee's separately listed model AL400ULM power supply.
<b>NOTES:</b>	

02-07-97



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 04/04/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division