

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

| LISTING No.: | 7315-1335:0117 |
|---------------|--|
| CATEGORY: | 7315 - POWER UNITS |
| LISTEE: | Altronix 140 58th Street, Bldg A, Ste 2N, Brooklyn, NY, 11220 Contact: Zatz, Gary (718) 567-8181 (718) 567-9056 Email: garyz@altronix.com |
| DESIGN: | Model Strikelt2 panic device power supply. The unit will operate up to one (1) 24VDC listed panic hardware device. One un-switched auxiliary voltage output is provided for powering listed card readers, keypads, REX PIRs, etc. All product outputs are power-limited. A Listed tamper switch must be installed for enclosure cover supervision. Indoor use only. Refer to listee's data sheet for additional detailed product description and operational considerations. |
| RATING: | Input: 115 VAC, 60 Hz, 7 A Max., Battery: 24 VDC, 4Ah Main Output (lock outputs): 24VDC rated @ 16 A for 300 ms, .5 A continuous # Auxiliary Output (filtered, regulated): 24 VDC rated @ .5 A continuous # |
| | # Note: Total combined current for the 24 VDC outputs may not exceed 1 A. |
| INSTALLATION: | In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. |
| MARKING: | Listee's name, model number, electrical rating, date of manufacture and UL label. |
| APPROVAL: | Listed as access control unit power supply for listed compatible panic hardware with separately listed compatible fire alarm control units. |
| NOTES: | |

02-03-2010 fm



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.



CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING & INVESTIGATIONS DIVISION BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

| Date Issued: 04/04/2024 | Listing Expires: 06/30/2025 |
|---|-----------------------------|
| Authorized By: David Castillo , Program Coordinator Fire Engineering & Investigations Division | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |