

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7315-1335:0117

Page 1 of 1

**CATEGORY:** 7315 -- POWER UNITS

**LISTEE:** Altronix140 - 58th Street, Bldg A-3W, Brooklyn, NY 11220  
Contact: Gary Zatz (718) 567-8181 Fax (718) 567-9056  
Email: garyz@altronix.com

**DESIGN:** Model Strikelt2 panic device power supply. The unit will operate up to one (1) 24VDC listed panic hardware device. One un-switched auxiliary voltage output is provided for powering listed card readers, keypads, REX PIRs, etc. All product outputs are power-limited. A Listed tamper switch must be installed for enclosure cover supervision. Indoor use only. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Input: 115 VAC, 60 Hz, 7 A Max., Battery: 24 VDC, 4Ah  
Main Output (lock outputs): 24VDC rated @ 16 A for 300 ms, .5 A continuous #  
Auxiliary Output (filtered, regulated): 24 VDC rated @ .5 A continuous #

# Note: Total combined current for the 24 VDC outputs may not exceed 1 A.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, date of manufacture and UL label.

**APPROVAL:** Listed as access control unit power supply for listed compatible panic hardware with separately listed compatible fire alarm control units.

02-03-2010 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**

*Fire Engineering Division*