



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7315-1335:0120
CATEGORY:	7315 - POWER UNITS
LISTEE:	Altronix 140 58th Street, Bldg A, Ste 2N, Brooklyn, NY, 11220 Contact: Zatz, Gary (718) 567-8181 (718) 567-9056 Email: garyz@altronix.com
DESIGN:	Models eFlow3, eFlow3N, eFlow3NX, eFlow3X, eFlow4, eFlow4N, eFlow4NX, eFlow4X, eFlow6, eFlow6N, eFlow6NX, eFlow6X, eFlow102, eFlow102N, eFlow102NX, eFlow102X, eFlow104, eFlow104N, eFlow104NX and eFlow104X Power Supply/Chargers. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	Models eFlow3, eFlow3X, eFlow3N, and eFlow3NX: Primary Operating Supply - 115 Vac, 60 Hz, 3.5 A Models eFlow4, eFlow4N, eFlow4NX, eFlow4X, eFlow6, eFlow6N, eFlow6NX, eFlow6X, eFlow102, eFlow102N, eFlow102NX, and eFlow102X: Primary Operating Supply - 120 Vac, 60 Hz, 3.5 A Models eFlow104, eFlow104N, eFlow104NX and eFlow104X: Primary Operating Supply - 120 Vac, 60 Hz, 4.5 A
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as power supply/charger units for use with separately listed compatible fire alarm control units for indoor use only. Refer to listee's Installation Instruction Manual for details.
NOTES:	

01-28-13 gt



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/10/2025

Listing Expires: 06/30/2026

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division