

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7315-1335:0120

Page 1 of 1

CATEGORY: 7315 -- POWER UNITS

LISTEE: Altronix140 - 58th Street, Bldg A-3W, Brooklyn, NY 11220
Contact: Gary Zatz (718) 567-8181 Fax (718) 567-9056
Email: garyz@altronix.com

DESIGN: Models eFlow3, eFlow3N, eFlow3NX, eFlow3X, eFlow4, eFlow4N, eFlow4NX, eFlow4X, eFlow6, eFlow6N, eFlow6NX, eFlow6X, eFlow102, eFlow102N, eFlow102NX, eFlow102X, eFlow104, eFlow104N, eFlow104NX and eFlow104X Power Supply/Chargers. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Models eFlow3, eFlow3X, eFlow3N, and eFlow3NX: Primary Operating Supply - 115 Vac, 60 Hz, 3.5 A
Models eFlow4, eFlow4N, eFlow4NX, eFlow4X, eFlow6, eFlow6N, eFlow6NX, eFlow6X, eFlow102, eFlow102N, eFlow102NX, and eFlow102X: Primary Operating Supply - 120 Vac, 60 Hz, 3.5 A
Models eFlow104, eFlow104N, eFlow104NX and eFlow104X: Primary Operating Supply - 120 Vac, 60 Hz, 4.5 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as power supply/charger units for use with separately listed compatible fire alarm control units for indoor use only. Refer to listee's Installation Instruction Manual for details.

01-28-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division