



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7315-1335:0123
<b>CATEGORY:</b>	7315 - POWER UNITS
<b>LISTEE:</b>	Altronix 140 58th Street, Bldg A, Ste 2N, Brooklyn, NY, 11220 Contact: Zatz, Gary (718) 567-8181 (718) 567-9056 Email: garyz@altronix.com
<b>DESIGN:</b>	Models eFlow4N8, eFlow4NX8, eFlow4N8D and eFlow4NX8D power supply/charger. Model number may be followed by additional alpha suffix indicating enclosure color. Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	120 V, 60 Hz, 3.5 A
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating, and UL label.
<b>APPROVAL:</b>	Listed as power supply/charger units for use with separately listed compatible fire alarm control units for indoor use only. Refer to listee's Installation Instruction Manual for details.
<b>NOTES:</b>	

11/20/2013 JP



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 04/03/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division