



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7315-1335:0502
CATEGORY:	7315 - POWER UNITS
LISTEE:	Altronix 140 58th Street, Bldg A, Ste 2N, Brooklyn, NY, 11220 Contact: Zatz, Gary (718) 567-8181 (718) 567-9056 Email: garyz@altronix.com
DESIGN:	Model R1042ULADA Notification Appliance Circuit Power Extender. Unit is a power supply/battery charger intended to provide expanded power capability for up to four notification appliance circuits (NAC) and can also provide auxiliary power to support system accessories. Refer to listee's data sheet for additional detailed product description and operational considerations.
RATING:	120 VAC input, 24 VDC output
INSTALLATION:	In accordance with listee's printed installation instructions, NFPA 70, NFPA 72, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as power supply unit for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.
NOTES:	

1-14-21 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/03/2024

Listing Expires: 06/30/2025



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division