

# AL300ULPD8R Multi-Output Power Supply/Charger



## <u>Overview</u>

AL300ULPD8R is a multi-output power supply/charger that converts a 115VAC/60Hz input into eight (8) Class 2 Rated 12VDC or 24VDC power-limited outputs.

#### Input:

- Input 115VAC, 60Hz, 3.5 amp.
- Input fuse rated @ 3.5 amp/250V.

## Output:

- 12VDC or 24VDC selectable output. Burglar Alarm Applications (UL 603): 12VDC = 10VDC-13.2VDC. 24VDC = 20VDC-26.4VDC.
- 2.5 amp total supply current.
- Filtered and electronically regulated output.
- Short circuit and thermal overload protection.

## **Battery Backup:**

- Built-in charger for sealed lead acid or gel type batteries.
- Automatic switch over to stand-by battery when AC fails.
- Maximum charge current 0.7 amp.

UL 294

# **Specifications**

#### Supervision:

- AC fail supervision (form "C" contacts).
  - Notification trigger is selectable for 30 seconds (factory set) or 6 hours.
- Low battery supervision (form "C" contacts).
- Battery presence supervision (form "C" contacts).

## Visual Indicators:

- AC input, DC output and Battery LED indicators. *Electrical:*
- Operating temperature: 0° C to 49° C ambient.
- BTU/Hr. :
- 12VDC: 14.71 16.63 BTU/Hr.
- 24VDC: 29.43 32.41 BTU/Hr.
- System AC input VA requirement: 402.5VA.

#### Mechanical:

- Enclosure Dimensions (H x W x D approx.): 13.5" x 13" x 3.25" (342.9mm x 330.2mm x 82.55mm)
  Accommodates up to two (2) 12VDC/7AH batteries.
- Product weight (approx.): 8.7 lbs. (3.95 kg).
- Shipping weight (approx.): 9.6 lbs. (4.35 kg).

# Agency Approvals



# UL Listed for Access Control System Units.

- UL 603 UL Listed Standard for Power Supplies for Use with Burglar Alarm Systems.
- UL 1069 UL Listed Hospital Signaling and Nurse Call Equipment.

UL 1481 UL Listed Standard for Safety for Fire Protective Signaling Systems.



General Signaling Equipment Evaluated to CSA Standard C22.2 No.205-M1983

