

### Specification Chart:


Model #	Input (Primary)	Output (Secondary)
T12175	115VAC, 50/60Hz, 1.6A	12VAC/175VA (14.5A)

### Installation Instructions:

1. Mount transformer in the desired location/enclosure (*refer to Transformer Drawing and Dimensions below*).
2. Connect AC power 115VAC, 50/60Hz to primary leads (black and white) from terminal numbers 1 and 2 (*refer to Wiring Configuration below*).
3. Measure output voltage across the secondary leads (yellow and blue) from terminal numbers 7 and 12 (*refer to Wiring Configuration below*) before connecting devices. This helps avoiding potential damage.
4. Connect 12VAC device to be powered to the secondary leads (yellow and blue) from terminal numbers 7 and 12 (*refer to Wiring Configuration below*).

**WARNING:** This installation should be made by qualified service personnel and should conform to the National Electrical Code and all local codes.

### Wiring Configuration:



### Transformer Drawing and Dimensions:

