

Altronix/Mercury Networked Kits

Models Include:

T2MK7F8SQ

8 Door Kit with Fused Outputs

Fully assembled kit includes:

- Trove2 enclosure with TM2 Altronix/Mercury backplane
- One (1) eFlow104NB - Power Supply/Charger
- One (1) LINQ8ACM - Networked Fuse Protected Access Power Controller
- One (1) VR6 - Voltage Regulator
- One (1) LINQ8PD - Networked Fuse Protected Power Distribution Module
- One (1) NetWay5B - 5-Port Hardened Switch Board
- One (1) BR1 - Mounting Bracket
- One (1) RSB1 - Rocker Switch Bracket with One (1) Rocker Switch

T2MK7F8SDQ

8 Door Kit with PTC Outputs

Fully assembled kit includes:

- Trove2 enclosure with TM2 Altronix/Mercury backplane
- One (1) eFlow104NB - Power Supply/Charger
- One (1) LINQ8ACMCB - Networked PTC Protected Access Power Controller
- One (1) VR6 - Voltage Regulator
- One (1) LINQ8PDCB - Networked PTC Protected Power Distribution Module
- One (1) NetWay5B - 5-Port Hardened Switch Board
- One (1) BR1 - Mounting Bracket
- One (1) RSB1 - Rocker Switch Bracket with One (1) Rocker Switch

Please refer to the included corresponding Sub-Assembly Installation Guides for further information.

Installation Guide



All registered trademarks are property of their respective owners.

Rev. 102424

Installing Company: _____ Service Rep. Name: _____

Address: _____ Phone #: _____



Overview:

Altronix T2MK7F8S(D)Q Trove Mercury kit is pre-assembled and consists of Trove2M2 enclosure with factory installed Altronix power supply/charger and sub-assemblies. T2MK7F8S(D)Q kit also accommodates various combinations of Mercury boards for up to eight (8) doors in a single enclosure.

Configuration Chart:

Altronix Model Number	120VAC 60Hz Input Current (A)	Power Supply Board Input Fuse Rating	Power Supply Board Battery Fuse Rating	Nominal DC Output Voltage		Maximum Supply Current for Main and Aux. Outputs on Power Supply board, LINQ8ACM(CB) Access Power Controller(s) and LINQ8PD(CB) outputs	Fail-Safe/Fail-Secure or Dry Form "C" Outputs	Additional Fuse (PTC) Protected Outputs	Current Per LINQ8ACM(CB) and LINQ8PD(CB) Output (A)	LINQ8ACM(CB) and LINQ8PD(CB) Board Input Fuse (PTC) Rating	LINQ8ACM(CB) and LINQ8PD(CB) Board Output Fuse (PTC) Rating	NetWay5B Switch Outputs
				[DC]	[Aux]							
T2MK7F8SQ	4.5	6.3A/250V	10A/32V	20.17-26.4	20.28-26.4	24VDC @ 9.6A	8	8	2.5	15A/32V	3A/32V	Five (5) data ports
T2MK7F8SDQ									2.0	9A	2.5A	

Installation Instructions:

Wiring methods shall be in accordance with the National Electrical Code/NFPA 70/ANSI, and with all local codes and authorities having jurisdiction. Product is intended for indoor use only.

1. Remove backplane from enclosure. Do not discard hardware.
2. Mark and predrill holes in the wall to line up with the top three keyholes in the enclosure. Install three upper fasteners and screws in the wall with the screw heads protruding. Place the enclosure's upper keyholes over the three upper screws; level and secure. Mark the position of the lower three holes. Remove the enclosure. Drill the lower holes and install the three fasteners. Place the enclosure's upper keyholes over the three upper screws. Install the three lower screws and make sure to tighten all screws.
3. Mount included UL Listed tamper switch (Altronix Model TS112 or equivalent) in desired location, opposite hinge. Slide the tamper switch bracket onto the edge of the enclosure approximately 2" from the right side (*Fig. 1, pg. 2*). Connect tamper switch wiring to the Access Control Panel input or the appropriate UL Listed reporting device. To activate alarm signal open the door of the enclosure.
4. Connect unswitched AC power (120VAC 60Hz) to terminals marked [L, N]. Use 14 AWG or larger for all power connections. Secure green wire lead to earth ground. Green "AC" LED on power supply board will turn on.

This light can be seen through the LED lens on the door of the enclosure.


Keep power-limited wiring separate from non power-limited wiring (120VAC 60Hz Input, Battery Wires). Minimum 0.25" spacing must be provided.

CAUTION: Do not touch exposed metal parts. Shut branch circuit power before installing or servicing equipment. There are no user serviceable parts inside.

Refer installation and servicing to qualified service personnel.

5. Measure voltage before connecting devices. This helps avoiding potential damage.
6. Mount Mercury modules to backplane(s), refer to *page 3*.
7. Refer to the *eFlow Power Supply/Charger Installation Guide* for eFlow104NB and corresponding *Sub-Assembly Installation Guides* for LINQ8ACM(CB), LINQ8PD(CB), NetWay5B and VR6 for further installation instructions.

Fig. 1



Hardware:

Snap On Spacer | 5/16" Pan Head Screw | Lock Nut

T2MK7F8S(D)Q: Configuration of Mercury Boards:


1. Fasten snap on spacers onto metal pems configuration (A), (B), (C) or (D) of backplane depending on the access controller (Fig. 2, pg. 3).
2. Position access controller module over corresponding spacers and depress onto snap on spacers (Fig. 2a, pg. 3).
3. Mount backplane to enclosure with hardware.

Access Controller Position Chart for the Following Models:

Mercury Access Controller	Pem Mounting
EP1502, MR52, MR16IN, MR16OUT	(A)
EP2500, MUX8	(B)
EP1501, MR51e	(C)
MR50	(D)


Fig. 2

Fig. 2a



Trove2 Enclosure Dimensions (H x W x D approximate):

27.25" x 21.75" x 6.5" (692.2mm x 552.5mm x 165.1mm)



Altronix is not responsible for any typographical errors.

140 58th Street, Brooklyn, New York 11220 USA | phone: 718-567-8181 | fax: 718-567-9056
 web site: www.altronix.com | e-mail: info@altronix.com | Lifetime Warranty
 IIT2MK7F8S(D)Q

J24X



T2MK7F8S(D)Q Installation Guide